



September 2017

Point Number	EPA Analyte	Guide Low Limit or Range Min	Guide High Limit or Range Max	Result
EPL#3	Aluminium	5	-	0.029
	Arsenic	0.5	-	<0.001
	BOD	30	-	<5
	Cadmium	0.01	-	<0.0001
	Chemical oxygen demand	-	-	19
	Chromium	1	-	<0.001
	Cobalt	1	-	<0.001
	Conductivity	800	-	430
	Copper	0.4	-	0.001
	Fluoride	2	-	0.30
	Lead	0.1	-	0.001
	Manganese	-	-	0.006
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	0.001
	Nickle	1	-	0.001
	Oil and Grease	10	-	<5
	pH	6.5	8.5	8.7
	Selenium	0.02	-	<0.001
	Sulfate	-	-	160
	Total Suspended solids	50	-	<5
	Zinc	20	-	<0.005
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	<0.1
EPL#4	Aluminium	5	-	0.020
	Arsenic	0.5	-	<0.001
	BOD	30	-	<5
	Cadmium	0.01	-	<0.0001
	Chemical oxygen demand	-	-	16
	Chromium	1	-	<0.001
	Cobalt	1	-	<0.001
	Conductivity	800	-	450
	Copper	0.4	-	0.001
	Fluoride	2	-	0.32
	Lead	0.1	-	<0.001
	Manganese	-	-	0.005
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	0.005
	Nickle	1	-	<0.001
	Oil and Grease	10	-	<5
	pH	6.5	8.5	8.7
	Selenium	0.02	-	<0.001
	Sulfate	-	-	150
	Total Suspended solids	50	-	<5
	Zinc	20	-	<0.005
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	0.1
EPL#5	Aluminium	5	-	0.038
	Arsenic	0.5	-	<0.001
	BOD	30	-	<5

	Cadmium	0.01	-	<0.0001
	Chemical oxygen demand	-	-	11
	Chromium	1	-	<0.001
	Cobalt	1	-	<0.001
	Conductivity	800	-	540
	Copper	0.4	-	0.001
	Fluoride	2	-	0.49
	Lead	0.1	-	<0.001
	Manganese	-	-	0.006
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	0.002
	Nickle	1	-	<0.001
	Oil and Grease	10	-	<5
	pH	6.5	8.5	7.9
	Selenium	0.02	-	<0.001
	Sulfate	-	-	180
	Total Suspended solids	50	-	<5
	Zinc	20	-	<0.005
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	0.1
EPL#6	Aluminium	5	-	0.046
	Arsenic	0.5	-	<0.001
	BOD	30	-	<5
	Cadmium	0.01	-	<0.0001
	Chemical oxygen demand	-	-	15
	Chromium	1	-	<0.001
	Cobalt	1	-	<0.001
	Conductivity	800	-	400
	Copper	0.4	-	0.002
	Fluoride	2	-	0.32
	Lead	0.1	-	<0.001
	Manganese	-	-	0.005
	Mercury	0.002	-	0.0001
	Molybdenum	0.15	-	0.003
	Nickle	1	-	<0.001
	Oil and Grease	10	-	<5
	pH	6.5	8.5	7.5
	Selenium	0.02	-	<0.001
	Sulfate	-	-	64
	Total Suspended solids	50	-	<5
	Zinc	20	-	<0.005
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	<0.1